



ATTESTATION of conformity with European Directives

Product: **MCCB**
Reference **TOS1-630 Series**
Issued to **WENZHOU TONGOU ELECTRICAL CO.,LTD**
Address **Paidong Industrial Zone,Qiligang,Yueqing City,Zhejiang province,China.**
Manufacturer **WENZHOU TONGOU ELECTRICAL CO.,LTD**
Ue: 400V~
Utilization category: A
Ie: 400A;500A;630A
50/60Hz
Icu=50kA
Ics=35kA
Technical characteristics **Ui= 800V**
Uimp=8kV
IP40 for front cover
Pollution degree: 3
Reference temperature: 40°C
Distance for metal screen:
Back:0mm Front:10mm; Top:100mm Botton:100mm; Left:30mm
Right:30mm(values declared by client)

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 60947-2:2017+A1:2020; EN 60947-1:2007 + A1:2011 + A2:2014	B200083	2020-11-23

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), December 9th, 2020.

Charlie CHEN
Product Line Manager



Information given in this document, are related to the tested specimen of the described electrical sample.